


**PCS-4-2X4-4L54-WG Open Fixture**  
**Relative Light Output in a Non-Conditioned Warehouse Space**

Ambient Temperature @ Floor Level		Ambient Temperature @ 28' Ceiling		Relative Light Output @ 28' Ceiling
Fahrenheit	Celsius	Celsius	Fahrenheit	
115	46	54	130	70%
111	44	52	126	75%
108	42	50	123	
104	40	48	119	80%
100	38	46	115	
97	36	44	112	85%
93	34	42	108	
90	32	40	105	
86	30	38	101	90%
82	28	36	97	95%
79	26	34	94	
75	24	32	90	
72	22	30	87	
68	20	28	83	100%
64	18	26	79	95%
61	16	24	76	
57	14	22	72	
54	12	20	69	
50	10	18	65	90%
46	8	16	61	
43	6	14	58	85%
39	4	12	54	
36	2	10	51	
32	0	8	47	80%
28	(2)	6	43	
25	(4)	4	40	75%
21	(6)	2	36	
18	(8)	0	33	70%
14	(10)	(2)	29	
10	(12)	(4)	25	60%
7	(14)	(6)	22	
3	(16)	(8)	18	40%
(0)	(18)	(10)	15	

**Note:**

- A temperature differential of +15 Degree Fahrenheit is used from floor level to warehouse ceiling.
- Per fixture relative light output are values from PRD controlled environment testing spring 2002 with (4)F54T5HO Lamps operating in an open PCS fixture.



# T5 4 Lamp Open Fixture

